

SIEĆ BADAWCZA ŁUKASIEWICZ INSTYTUT TECHNOLOGII DREWNA

WOOD TECHNOLOGY INSTITUTE • INSTITUT FÜR HOLZTECHNOLOGIE • INSTITUT DE TECHNOLOGIE DU BOIS WINIARSKA 1 • 60-654 POZNAŃ – POLAND • phone: +48 61 849-24-00 • fax: +48 61 822-43-72 e-mail: office@itd.poznan.pl • http://www.itd.poznan.pl Notified Body N° 1583

Poznań, 5th July2019

Reaction to fire classification report

1 Introduction

This classification report defines the classification assigned to sports floor Lumaflex Duo Linosport xf² with a thickness of 3.2 mm, in accordance with the procedures given in PN-EN 13501-1+A1:2010 [EN 13501-1:2007+A1:2009].

CLASSIFICATION OF REACTION TO FIRE IN ACCORDANCE WITH PN-EN 13501-1+A1:2010

| Customer: | Tarkett Polska Sp. z o.o. ul. Miłosławska 13A 62-322 ORZECHOWO |
|----------------------------|--|
| Prepared by: | Sieć Badawcza Łukasiewicz - Instytut Technologii Drewna Winiarska Str.1 60-654 Poznań Poland |
| Notified Body No | 1583 |
| Product name: | sports floor Lumaflex Duo Linosport xf ² with a thickness of 3.2 mm, with protective UV-cured polyurethan coating |
| Classification report No.: | 8/2019 |
| Issue number: | 1 |
| Date of issue: | 5 th July 2019 |
| | |

This classification report consists of four pages and may only be used or reproduced in its entirety.

2 Details of classified product

2.1 General

The product, sports floor Lumaflex Duo Linosport xf^2 with a thickness of 3.2 mm, with protective UV-cured polyurethan coating, is defined as a flooring.

2.2 Product description

The product: The sports floor Lumaflex Duo Linosport xf^2 consists of three layers: top layer – Linoleum Linosport xf^2 with a thickness of 3.2 mm with protective UV- cured polyurethane coating, middle layer - birch plywood with a thickness of 18 mm, bottom layer - "Tarfoam 60" polyurethane foam.

The top layer was adhered to the grid of plywood with a thickness of 18 mm using a dispersion adhesive for linoleum.

The Lumaflex Duo floor is installed in a floating system - not glued to the ground/support.

The tested samples were laid on a standard support: 8 mm fiber-cement board.

3 Reports and results in support of this classification

3.1 Reports

| Name of Laboratory | Name of sponsor | Report ref. no. | Test method and date Field of application rules and date |
|---|--|--|--|
| Wood, Wood-Based Materials, Packaging, Furniture, Wooden Constructions and Woodworking Machines Testing Laboratory of Łukasiewicz Research Network - Wood Technology Institute in Poznań | Tarkett Polska Sp. z o.o. ul. Miłosławska 13A 62-322 Orzechowo | 1534/2019/S.K record no. 1/1534/2019/S.K | EN ISO 9239-1 (radiant heat source method) 25.06.2019 direct application |
| Wood, Wood-Based Materials, Packaging, Furniture, Wooden Constructions and Woodworking Machines Testing Laboratory of Łukasiewicz Research Network - Wood Technology Institute in Poznań | Tarkett Polska Sp. z o.o. ul. Miłosławska 13A 62-322 Orzechowo | 1534/2019/S.K record no. 2/1534/2019/S.K | EN ISO 11925-2 (direct impingement of single flame method) 18.06.2019 direct application |

3.2 Results

| Test method and test number | | | Results | |
|---|--|--------------|---------------------------------------|----------------------------------|
| | Parameter | No. Tests | Continuous parameter – mean (m) | Compliance with parameters |
| EN ISO 9239-1 (radiant heat source method) A-1534-BOŚ/2019/6K | Critical heat flux (kW/m²) | | 6.31 | () |
| | Smoke production (%·min) | 4 | 194.31 | () |
| EN ISO 11925-2 (direct impingement of single flame method) Exposure time: 15 s A-1534-BOŚ/2019/7K | The flame spread <i>F</i> s ≤ 150 mm within 20 s from the time of application | 6 | () | YES |

(-):not applicable

4 Classification and field of application

4.1 Reference of classification

This classification has been carried out in accordance with PN-EN 13501-1+A1:2010.

4.2 Classification

The product, sports floor Lumaflex Duo Linosport xf^2 consisting of top layer – Linoleum Linosport xf^2 with a thickness of 3.2 mm with protective UV- cured polyurethane coating, adhered to the grid of plywood (middle layer) with a thickness of 18 mm using a dispersion adhesive for linoleum and of bottom layer - "Tarfoam 60" polyurethane foam, installed in a floating system, in relation to its reaction to fire behavior is classified:

Cfl

The additional classification in relation to smoke production is:

s1

The format of the reaction to fire classification for floorings is:

| Fire behavior | | Smoke production | | |
|-----------------|---|------------------|---|--|
| C _{fl} | - | s | 1 | |

i.e.: CfI-s1

Reaction to fire classification: Cfl-s1

4.3 Field of application

This classification is valid for the following product parameters described in section 2.2:

The product, the sports floor Lumaflex Duo Linosport xf^2 consisted of three layers: top layer – Linoleum Linosport xf^2 with a thickness of 3.2 mm with protective UV- cured polyurethane coating, middle layer - birch plywood with a thickness of 18 mm, bottom layer - "Tarfoam 60" polyurethane foam.

The top layer was adhered to the grid of plywood with a thickness of 18 mm using a dispersion adhesive for linoleum.

The Lumaflex Duo floor is installed in a floating system - not glued to the ground/support.

(Test report no. 1534/2019/S.K of 28^h June 2019)

This classification is valid for the following end use applications:

- The product is used only on bases or floors with reaction to fire class A1 or A2-s1, d0
- The product used in a horizontal position with the exposed side up.

5 Limitations

This classification document does not represent type approval or certification of the product.

This document is valid provided that neither the composition nor production technology of the product are changed, but not longer than until 5th July 2024.

VERIFIED BY

Dr Hanna Wróblewska, Prof. of Wood Technology Institute